

**BEFORE THE KARNATAKA ELECTRICITY REGULATORY COMMISSION  
BANGALORE**

**Dated this 30<sup>TH</sup> DAY OF NOVEMBER 2006**

- |    |                     |    |          |
|----|---------------------|----|----------|
| 1. | Shri K.P.Pandey     | .. | Chairman |
| 2. | Shri H.S.Subramanya | .. | Member   |
| 3. | Shri S.D.Ukkali     | .. | Member   |

**Case No.OP 17 / 2005**

**Between:**

M/s.Nuziveedu Seeds Limited,  
# 7C, "Surya Towers",  
Sardar Patel Road,  
**SECUNDERABAD(AP)-500003**

.. **Petitioner**

**And**

The Managing Director  
Karnataka Power Transmission Corporation Limited  
Cauvery Bhavan,  
**Bangalore-560009**

.. **Respondent**

The Petitioner company has set up a wind power project with a capacity of 6.75 MW and had entered into an agreement with the KPTCL on 29.10.2001. They had synchronized 3.75 MW with the grid system. It is submitted that as per the initial approval accorded by the Respondent, the Petitioner company had charged 33 KV line of 11 KV and subsequently set up a 0.5 class accuracy meter for metering the energy supplied to the grid. However, while approving the synchronization on 30.3.2001, the Respondent had clarified that as per the new norms, a 0.2 class accuracy meter has to be installed. Subsequently, the Petitioner had replaced the 0.5 class accuracy meter with 0.2 class accuracy meter. However, the CT/PT's suitable for the above said meter could not be

..2...

replaced. The Petitioner company installed the suitable CT/PT/s on 28.05.2001. During the process of changing the meter as referred to above along with suitable CT/PT's, the Petitioner had supplied energy to the extent of 6,36,000 KWH worth Rs.20,09,760.00 to the grid. However, no payment has been made in respect of this supply of power in spite of representations made to the Respondent. In the Petition filed before the Commission, the Petitioner has prayed for issue of appropriate directions to the Respondent to release payment of Rs.20,09,760.00 for the electricity supplied by the Petitioner in terms of the PPA dated 29.10.2001.

Both the parties were heard on the dispute raised by the Petitioner. In the course of the hearing, both the parties have filed a Joint Memo stating the following:

**JOINT MEMO**

"Both the parties have discussed and have agreed to account the energy supplied by the Company during the period from 31.03.2001 to 28.05.2001 by providing only 0.5 Class accuracy meter will be paid by deducting 0.6% of energy supplied towards the difference between the 0.2 Class accuracy meter which was required to be put as per the PPA and 0.5 Class accuracy meter which was actually provided.

The above may kindly be recorded and the Petition may be disposed off in terms of the same.

ADVOCATE FOR PETITIONER

for NUZIVEEDU SEEDS LTD.

ADVOCATE FOR RESPONDENT

for KARNATAKA POWER TRANSMISSION  
CORPORATION LIMITED"

In terms of the above settlement, the Petition is disposed off and the parties are directed to abide by the terms of the said Joint Memo.

Sd/-  
(K.P.Pandey)  
Chairman

Sd/-  
(H.S.Subramanya)  
Member

Sd/-  
(S.D.Ukkali)  
Member