


ENERGY FLOW DIAGRAM FOR
TRANSMISSION LOSSES (2020-21)

Form T - 19

INPUT ENERGY IN KPTCL GRID = 71271.69 MU
ENERGY AT INTERFACE POINT = 69105.43 MU
PERCENTAGE TRANS LOSSES = 3.039%



ENERGY SOLD BY ESCOM

TOTAL ENERGY INPUT FROM 33KV & 11KV

LINE AND TRANSFORMER LOSSES

PAVAGADA SOLAR PARK
2000 MW